

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Fuse-link, NH-System

Name and address of the applicant

VOLTRAN Elektrotechnik  
Sanayi ve Ticaret A.S.  
Yeltekin Is Merkezi No. 23/6, 34295 SEFAKÖY  
KÜCÜKCEKMECE, Istanbul / TURKEY

Name and address of the manufacturer

VOLTRAN Elektrotechnik  
Sanayi ve Ticaret A.S.  
Yeltekin Is Merkezi No. 23/6, 34295 SEFAKÖY  
KÜCÜKCEKMECE, Istanbul / TURKEY

Name and address of the factory

VOLTRAN Elektrotechnik Sanayi ve Ticaret A.S.  
Yeltekin Is Merkezi No. 23/6, 34295 SEFAKÖY  
KÜCÜKCEKMECE, Istanbul  
TURKEY

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

NH2; 200A to 400A; 500V AC; I1 = 120kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

23.4xxx.80

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60269-1:2006  
IEC 60269-1:2006/AMD1:2009  
IEC 60269-1:2006/AMD2:2014  
IEC 60269-2:2013  
IEC 60269-2:2013/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

234380-TL3-1; 234380-TL3-2

This CB Test Certificate is issued by the National Certification Body

**VDE** Prüf- und Zertifizierungsinstitut GmbH  
**VDE** Testing and Certification Institute  
Zertifizierung Produkte / Certification Products

A handwritten signature in blue ink, appearing to read 'J. Richter'.

Date: 2018-07-27

Signature:

J. Richter