

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fuse-link, NH-System

Name and address of the applicant

VOLTRAN Elektrotechnik
Sanayi ve Ticaret A.S.
Yeltekin Is Merkezi No. 23/6, 34295 SEFAKÖY
KÜCÜKCEKMECE, Istanbul

Name and address of the manufacturer

VOLTRAN Elektrotechnik
Sanayi ve Ticaret A.S.
Yeltekin Is Merkezi No. 23/6, 34295 SEFAKÖY
KÜCÜKCEKMECE, Istanbul

Name and address of the factory

VOLTRAN Elektrotechnik Sanayi ve Ticaret A.S.
Yeltekin Is Merkezi No. 23/6, 34295 SEFAKÖY
KÜCÜKCEKMECE, Istanbul
TURKEY

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

NH00; 63A to 160A; 500V AC; I1 = 120kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

23.1xxx.80

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60269-1:2006
IEC 60269-1:2006/AMD1:2009
IEC 60269-1:2006/AMD2:2014
IEC 60269-2:2013
IEC 60269-2:2013/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

244260-TL3-1; 244260-TL3-2

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE Testing and Certification Institute
Zertifizierung Produkte / Certification Products

Date: 2018-07-27

Signature:

G. Heine